

MINOR ELECTRICAL INSTALLATION WORKS

To be used only for minor electrical work which does not include the provision of a new circuit

Certificate Reference:

PLGS160601-209

1 DETAILS OF THE MINOR WORKS

Client address:		Installation address:	Same as Client Address
Description of the minor works:	Supply to garden shed (Sockets and light)		
Details of departures, if any, from BS 7671:2008 as amended:	None		
Details of permitted exceptions (Regulation 411.3.3):	None		
Date minor works completed:	01/06/2016	Risk assessment attached:	N/A

2 INSTALLATION DETAILS

System type and earthing arrangements:	TN-C-S	N/A	TN-S	N/A	TT	<input checked="" type="checkbox"/>	IT	N/A
Method of fault protection:	ADS							
Protective device for the modified circuit:	BS (EN):	60898 MCB	Type:	B	Rating:	20	A	
Residual current device (if applicable):	BS (EN):	61008 RCD	Type:	N/A	Rating:	30	mA	
Wiring type of the modified circuit:	Type:	PVC/PVC cables	Reference Method:	C	Live csa:	2.5 mm ²	cpc conductor csa	2.5 mm ²
	Maximum disconnection time permitted by BS 7671:	0.4	s	Maximum Zs permitted by BS 7671:	2.19	Ω		
Comments, if any, on existing installation, including adequacy of earthing and bonding arrangements (See Regulation 132.16):	None							

3 ESSENTIAL TESTS

Necessary inspections have been undertaken:	<input checked="" type="checkbox"/>	Protective bonding satisfactory:	<input checked="" type="checkbox"/>	Instrument Serial No(s):	
Earth continuity satisfactory:	<input checked="" type="checkbox"/>	Polarity satisfactory:	<input checked="" type="checkbox"/>	Multifunctional:	101077575
Circuit resistance:		Maximum measured earth fault loop impedance Zs:	0.76 Ω	Continuity:	N/A
R1+R2:	0.21 Ω or R2:	RCD operation (if applicable):		Insulation resistance:	N/A
Insulation resistance:		Disconnection time at In:	35 ms	Earth fault loop impedance:	N/A
Live - Live:	N/A MΩ	Disconnection time at 5In:	28 ms	RCD:	N/A
Live - Earth:	> 999 MΩ	Satisfactory test button operation:	<input checked="" type="checkbox"/>		

4 DECLARATION

I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS 7671:2008 (IET Wiring Regulations), amended to 2015, and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title:		Registration Number (if applicable):		
Address:		Telephone Number:		
	Postcode:			
Name:		Profession:	Electrician	
	Signature:		Date:	01/06/2016

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

GUIDANCE FOR RECIPIENT (to be appended to the Certificate)

This Certificate has been issued to confirm that the electrical installation work to which it relates to has been designed, constructed and inspected and tested in accordance with British Standard 7671, (the IET Wiring Regulations). You should have received an 'original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner.

A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

The Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the Certificate was issued.